

SERTIFIKAT O KONTROLISANJU
INSPECTION CERTIFICATE

Broj / Number: **T 1611**

Strana / Page: **1/2**

Na zahtev naručioca /
By the request of purchaser:

Robert Bosch d.o.o. ; Milutina Milankovića 9ž ; 11 070 Beograd
Srbija/Serbia

preduzeto je/
set to:

kontrolisanje novog proizvoda
the new product inspection

u vezi sa Izveštajem o kontrolisanju /
in relation to Inspection report:

Broj / Number: **T 1611**

sa dokumentima u prilogu/
with enclosed documents:

- Prospekt proizvoda /
Catalogue pages of product;
- Uputstvo za instaliranje i korišćenje /
Installation and user's manual;
- Dokumentacija o proizvodu / *Product documentation;*
- Izveštaj o ispitivanju Kiwa broj 130601391; / *Test report*
by Kiwa No. 130601391

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet kontrolisanja /
the inspection object :

GASNI KOTAO
GAS BOILER

proizveden od /
manufactured by :

Bosch Thermotechnik GmbH, D-73249 Wernau, Germany

oznaka - tip - serija /
mark - type - series :

BOSCH CONDENS 5000 W ZBR...

vrsta/type: B₂₃, C_{13X}, C_{33X}
kategorija/category: II_{2H3P}

kako je specificirano u Prilogu A, zadovoljava zahteve navedene u /
as specified in the Annex A, meets the requirements listed in:

referentnom dokumentu /
reference document :

SRPS EN 15502-2-1: 2013

Sertifikat o kontrolisanju se izdaje na osnovu standarda SRPS ISO/IEC 17020:2012 .
The inspection certificate is issued on the basis of standard SRPS ISO/IEC 17020:2012.

Nadzor usaglašenosti predmeta kontrolisanja se obezbeđuje sa
periodičnim kontrolisanjem do dana /

Surveillance of the inspection object compliance is assured by periodical
inspection until the date :

20.07.2021.

mesto, datum / place, date

Beograd, 20.07.2016.

izdat od / issued by :

RUKOVODILAC CENTRA ZA GASNU TEHNIKU
GAS TECHNIQUE CENTRE MANAGER

Kristina Petković, M.Sc.M.E.

SERTIFIKAT O KONTROLISANJU
INSPECTION CERTIFICATE

Broj / Number:

T 1611

Strana / Page:

2/2

Prilog A /

Annex A

oznaka - tip - serija /

mark - type - series :

BOSCH CONDENS 5000 W ZBR...

vrsta/type: B₂₃, C_{13X}, C_{33X}

kategorija/category: II_{2H3P}

detaljno oznaka - tip - serija / mark - type - series specification :	tehničke karakteristike / technical characteristics :	kratak opis / short description :
BOSCH CONDENS 5000 W		
ZBR 70-3	2H: p=20 mbar Q _n =13,3÷64,3 kW (Hi) P _n =13,0÷62,6 kW ^{1.)} P _n =14,3÷69,5 kW ^{2.)}	PMS=4 bar, T _{max} =90°C 230 V, 50 Hz, IP X4D NO _x : 5
100-3	2H: p=20 mbar Q _n =19,3÷96,5 kW (Hi) P _n =19,0÷94,5 kW ^{1.)} P _n =20,8÷99,5 kW ^{2.)}	- za grejanje/ for heating
Napomene / notes: 1.) pri / at: t ₂ /t ₁ =80/60°C 2.) pri / at: t ₂ /t ₁ =50/30°C		